

# Energy Performance Certificate

## Non-Domestic Building



Bell Inn  
13 Market Place  
FARINGDON  
SN7 7HP

**Certificate Reference Number:**  
0994-3000-0012-0490-0271

This certificate shows the energy rating of this building. It indicates the energy efficiency of the building fabric and the heating, ventilation, cooling and lighting systems. The rating is compared to two benchmarks for this type of building: one appropriate for new buildings and one appropriate for existing buildings. There is more advice on how to interpret this information on the Government's website [www.communities.gov.uk/epbd](http://www.communities.gov.uk/epbd).

### Energy Performance Asset Rating

More energy efficient

**A+**

Net zero CO<sub>2</sub> emissions

**A** 0-25

**B** 26-50

**C** 51-75

**D** 76-100

**E** 101-125

**F** 126-150

**G** Over 150

◀ **121**

This is how energy efficient the building is.

Less energy efficient

### Technical information

Main heating fuel:	Oil
Building environment:	Heating and Natural Ventilation
Total useful floor area (m <sup>2</sup> ):	755
Building complexity (NOS level):	3

### Benchmarks

Buildings similar to this one could have ratings as follows:

**53** If newly built

**73** If typical of the existing stock

# Recommendation Report



**Report Reference Number: 0090-0441-9020-4070-2092**

Bell Inn  
13 Market Place  
FARINGDON  
SN7 7HP

Building Type(s): Hotel

## ADMINISTRATIVE INFORMATION

Issue Date:	14 Dec 2009
Valid Until:	13 Dec 2019 (*)
Total Useful Floor Area (m <sup>2</sup> ):	755
Calculation Tool Used:	iSBEM v3.4.a using calculation engine SBEM v3.4.a
Property Reference:	942024090000
Energy Performance Certificate for the property is contained in Report Reference Number: 0994-3000-0012-0490-0271	

## ENERGY ASSESSOR DETAILS

Assessor Name:	Mr Mark Morris
Employer/Trading Name:	Viridian UK
Employer/Trading Address:	115 Bradley Road, Trowbridge
Assessor Number:	QUID200532
Accreditation scheme:	Quidos Ltd
Related Party Disclosure:	None

## **Table of Contents**

1. Background.....	3
2. Introduction.....	3
3. Recommendations.....	4
4. Next Steps.....	6
5. Glossary.....	8

## 1. Background

Statutory Instrument 2007 No. 991, *The Energy Performance of Buildings (Certificates and Inspections) (England and Wales) Regulations 2007*, as amended, transposes the requirements of Articles 7.2 and 7.3 of the Energy Performance of Buildings Directive 2002/91/EC.

This report is a Recommendation Report as required under regulations 16(2)(a) and 19 of the Statutory Instrument SI 2007:991.

This section provides general information regarding the building:

Total Useful Floor Area (m <sup>2</sup> ):	755
Building Environment:	Heating and Natural Ventilation

## 2. Introduction

This Recommendation Report was produced in line with the Government's approved methodology and is based on calculation tool iSBEM v3.4.a using calculation engine SBEM v3.4.a .

In accordance with Government's current guidance, the Energy Assessor did undertake a walk around survey of the building prior to producing this Recommendation Report.

## 4. Next steps

### **a) Your Recommendation Report**

As the building occupier, regulation 10(1) of SI 2007:991 requires that an Energy Performance Certificate "*must be accompanied by a recommendation report*".

You must be able to produce a copy of this Recommendation Report within seven days if requested by an Enforcement Authority under regulation 39 of SI 2007:991.

This Recommendation Report has also been lodged on the Government's central register. Access to the report, to the data used to compile the report, and to previous similar documents relating to the same building can be obtained by request through the Non-Dwellings Register ([www.epcregister.com](http://www.epcregister.com)) using the report reference number of this document.

### **b) Implementing recommendations**

The recommendations are provided as an indication of opportunities that appear to exist to improve the building's energy efficiency.

The calculation tool has automatically produced a set of recommendations, which the Energy Assessor has reviewed in the light of his / her knowledge of the building and its use. The Energy Assessor may have comments on the recommendations based on his / her knowledge of the building and its use. The Energy Assessor may have inserted additional measures in section 3d (Other Recommendations). He / she may have removed some automatically generated recommendations or added additional recommendations.

These recommendations do not include matters relating to operation and maintenance which cannot be identified from the calculation procedure.

The building has been identified as being: one of special architectural or historical interest, in a conservation area, in a designated area of special character or appearance (e.g. a national park, an AoNB), or of traditional construction. Some of the recommendations provided with this report may not be suitable for such a building, some may need special consents, and other measures may be available. Further information and guidance is available on the English Heritage website ([www.english-heritage.org.uk/epbd](http://www.english-heritage.org.uk/epbd)).

**c) Legal disclaimer**

The advice provided in this Recommendation Report is intended to be for information only. Recipients of this Recommendation Report are advised to seek further detailed professional advice before reaching any decision on how to improve the energy performance of the building.

**d) Complaints**

Details of the assessor and the relevant accreditation scheme are on this report and the energy performance certificate. You can get contact details of the accreditation scheme from our website at [www.communities.gov.uk/epbd](http://www.communities.gov.uk/epbd), together with details of their procedures for confirming authenticity of a certificate and for making a complaint.

## 5. Glossary

### ***a) Payback***

The payback periods are based on data provided by Good Practice Guides and Carbon Trust energy survey reports and are average figures calculated using a simple payback method. It is assumed that the source data is correct and accurate using up to date information.

The figures have been calculated as an average across a range of buildings and may differ from the actual payback period for the building being assessed. Therefore, it is recommended that each suggested measure be further investigated before reaching any decision on how to improve the energy efficiency of the building.

### ***b) Carbon impact***

The High / Medium / Low carbon impact indicators against each recommendation are provided to distinguish, between the suggested recommendations, those that would have most impact on carbon emissions from the building. For automatically generated recommendations, the carbon impact indicators are determined by software, but may have been adjusted by the Energy Assessor based on his / her knowledge of the building. The impact of other recommendations are determined by the assessor.

### ***c) Valid report***

A valid report is a report that has been:

- Produced within the past 10 years
- Produced by an Energy Assessor who is accredited to produce Recommendation Reports through a Government Approved Accreditation Scheme
- Lodged on the Register operated by or on behalf of the Secretary of State.

## Administrative information

This is an Energy Performance Certificate as defined in SI2007:991 as amended

**Assessment Software:** iSBEM v3.4.a using calculation engine SBEM v3.4.a  
**Property Reference:** 942024090000  
**Assessor Name:** Mr Mark Morris  
**Assessor Number:** QUID200532  
**Accreditation Scheme:** Quidos Ltd  
**Employer/Trading Name:** Viridian UK  
**Employer/Trading Address:** 115 Bradley Road, Trowbridge  
**Issue Date:** 14 Dec 2009  
**Valid Until:** 13 Dec 2019 (unless superseded by a later certificate)  
**Related Party Disclosure:** None

**Recommendations for improving the property are contained in Report Reference Number: 0090-0441-9020-4070-2092**

## If you have a complaint or wish to confirm that the certificate is genuine

Details of the assessor and the relevant accreditation scheme are on the certificate. You can get contact details of the accreditation scheme from the Government's website at [www.communities.gov.uk/epbd](http://www.communities.gov.uk/epbd), together with details of the procedures for confirming authenticity of a certificate and for making a complaint.



For advice on how to take action and to find out about technical and financial assistance schemes to help make buildings more energy efficient visit [www.carbontrust.co.uk](http://www.carbontrust.co.uk) or call us on 0800 085 2005



### 3. Recommendations

The following sections list recommendations selected by the energy assessor for the improvement of the energy performance of the building. The recommendations are listed under four headings: short payback, medium payback, long payback, and other measures.

#### ***a) Recommendations with a short payback***

This section lists recommendations with a payback of less than 3 years:

<b>Recommendation</b>	<b>Potential impact</b>
Install more efficient water heater.	HIGH
Replace tungsten GLS lamps with CFLs: Payback period dependent on hours of use.	LOW
Some spaces have a significant risk of overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.	MEDIUM
Replace tungsten GLS spotlights with low-voltage tungsten halogen: Payback period dependent on hours of use.	LOW
Consider replacing T8 lamps with retrofit T5 conversion kit.	LOW
Consider replacing heating boiler plant with high efficiency type.	HIGH
Add optimum start/stop to the heating system.	MEDIUM

#### ***b) Recommendations with a medium payback***

This section lists recommendations with a payback of between 3 and 7 years:

<b>Recommendation</b>	<b>Potential impact</b>
Some walls have uninsulated cavities - introduce cavity wall insulation.	HIGH
Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required.	LOW
Some windows have high U-values - consider installing secondary glazing.	HIGH
Add weather compensation controls to heating system.	MEDIUM
Add local time control to heating system.	MEDIUM

Consider replacing heating boiler plant with a condensing type.	HIGH
---	------

### ***c) Recommendations with a long payback***

This section lists recommendations with a payback of more than 7 years:

<b>Recommendation</b>	<b>Potential impact</b>
Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	HIGH
Some glazing is poorly insulated. Replace/improve glazing and/or frames.	HIGH
Consider installing solar water heating.	LOW

### ***d) Other recommendations***

This section lists other recommendations selected by the energy assessor, based on an understanding of the building, and / or based on a valid existing energy report.

No recommendations defined by the energy assessor have been identified